Deck Plan Submittal

Deck Size (overall dimensions): X	
Note: All fasteners MUST be Exterior grade.	. ,
Guardrail: - Required if floor is 30" or more above ground Constructed so no opening will allow a 4" sphere to pass thru Must withstand 200 lb. Side Load.	
Stairs (where applicable): - No. of Treads (9" min.): - No. of Risers (8½" max.): - Min. 4" high toe kick. Handrail: - Constructed so no opening will allow 4-3/8" sphere to pass thru. - See details below for acceptable Handrails.	36" Min: Height
- Material: - Size (nominal): - Material: - Material: - Material: - Size (nominal): - Size (nominal): - Size (nominal): - Spacing Center to Center: - Clear span distance: - Clear span distance:	
Carrier Beam: - Material: - Size (nominal): - Spacing Center to Center: - Clear span distance: - Material: - Material: - Size (nominal): - Size (nominal): - Post Length: - Provide Handrail Detail	
Footer: ————————————————————————————————————	type
- Depth (below grade): - Size: X [4x4 Post - 8"Ø] [6x6 Post - 10°Ø]	




Figure 3.14: Stair Geometry




Figure 3.15: Handrails and Guards

Handrails R311.5.6

- Shall be provided on all stairs with four (4) or more risers.
- Shall not reduce the clear width by > 4.5" when installed on one side or > than 9" when installed on both sides.
- Shall be between 34" and 38" high measured from nose of the tread.
- Handrails shall be continuous for the full length of the stairs.
 - o Handrails shall either be returned to a wall or terminate in a newel post.
 - O Handrails shall have a minimum of 1½" clearance between the rail and the wall.




Figure 3.16: Handrail Grip Size